

EIB 741 Software =====

1. Contents -----

/EIB_741	
/doc	
/de	Documentation and license conditions in German
/en	Documentation and license conditions in English
/labview	
/examples	Examples
/subvi	General VIs
/typedefs	Type definitions for the VIs
/VIs	LabView VIs for the EIB 741
eib7_top.mnu	Function pallet of all VIs for the EIB 741
/linux	
/examples	Examples
/c_cpp	Examples for C and C++ programming languages
/include	Header file for the functions of the EIB 741
/lib	Functions library for the EIB 741 (SO library)
/tools	Help programs for the EIB 741
/windows	
/bin	DLL for the EIB 741
/examples	Examples
/c_cpp	Examples for C and C++ programming languages
/include	Header file for the functions of the EIB 741
/lib	Library for the EIB 741 (LIB file)
/tools	Help programs for the EIB 741

2. Requirements -----

Labview:
 Version 8.0 or higher

Linux:
 Libraries: pthread
 The SO library was created with
 - kernel 2.6.9
 - gcc 3.4.3
 - libc 2.3.4

windows:
 Operating system: windows 2000, windows XP, windows Vista, windows 7
 Libraries: user32.lib, ws2_32.lib, kernel32.lib

3. Initial Setup -----

Installing the software -----

As described in the manual, the driver files (eib7.dll or libeib7.so) must be copied from the CD to the system directory. After this the contents of the "EIB_741" folder on the CD must be copied to any directory on the local hard disk. The examples and tools can then be used.

Establishing a network connection to the EIB 741

During initial setup, the EIB 741 must be connected to the computer via a point-to-point network connection and then configured. Before connecting the network cable to the computer, the following TCP/IP configuration must be set for the network card used:

- Use specific IP address (do not automatically procure)
- IP address: 192.168.1.1
- Subnet mask: 255.255.255.0

Once these settings have been entered, the network cable must be connected to the computer and the EIB 741, and the EIB 741 must be switched on. The EIB 741 is ready for operation as soon as the STATUS LED is lit.

Testing the connection

It is recommended that you first test via a ping command (DOS console or Linux shell) whether the EIB 741 can be addressed over the network. This should be the case if all steps have been followed correctly.

Command:
ping 192.168.1.2

The console reports whether the EIB 741 can be addressed. If it can, then the tools and example programs can be used. In some of these programs the IP address of the EIB 741 must be entered. The factory default setting for the EIB 741 is 192.168.1.2.

If the network parameters of the EIB 741 have already been changed, then the EIB 741 cannot be addressed via the standard IP address (192.168.1.2). If this is the case, then booting with the standard network settings is recommended. (See Installation Instructions, "Reset Modes" section)

Configuration of the network parameters of the EIB 741

This is done with the "networksettings" tool (see below). It is used to configure the EIB 741 for your network environment.

Running the examples and tools

The programs included for windows and Linux are run directly by the console (shell). The LabView programs are available as VIs.

4. Examples

----- C/C++ examples for windows and Linux

AuxAxis:

The position values of the encoder at axis 1 can be saved via two different trigger sources. The auxiliary axis is used for this purpose. An encoder with incremental signals must be connected to axis 1. The position values are saved periodically via the internal timer trigger. At the same time, the position can be saved with a second, asynchronous trigger signal.

easy:

Axis 1 of the EIB 741 is initialized for encoders with incremental signals. The position value and status word of this axis are requested and displayed. The IP address of the EIB 741 must be 192.168.1.2.

eib7info:

The device data of the EIB 741 firmware is read. This includes the serial number and MAC address as well as the network parameters. All data is output to the console. The IP address of the EIB 741 is interrogated after the program has been started.

IntervalCounter:

The encoder at axis 1 generates trigger pulses depending on the current position. The position of axis 2 is saved and displayed via this trigger source.

MatchIncrEnDat:

The absolute and incremental positions of an EnDat01 encoder are read and displayed simultaneously.

polling:

The position value and status word for an axis of the EIB 741 are read and displayed. The EIB 741 is operated in Polling mode for this. The user can select the axis whose position values are to be read. The program also interrogates the type of encoder interface. The user can choose between Incremental, EnDat 2.1 and EnDat 2.2. The position values are continually read in a loop. The IP address of the EIB 741 must be entered after the program has been started.

PulsCounter:

The EIB 741 is operated in Recording mode and a selectable axis is configured for incremental encoders. Triggering occurs via the internal timer trigger. The trigger pulses are started via a software trigger and are limited to a defined number by the PulsCounter.

softrealtime:

The position value, status word, timestamp and trigger counter for an axis of the EIB 741 are read and displayed. The EIB 741 is operated in Soft Realtime mode for this. Data for four axes is transmitted. The user can select which of the four axes is to be displayed.

Furthermore, the user can choose between external and internal triggering.

The position values are continually read in a loop. The IP address of the EIB 741 is interrogated after the program has been started.

SoftrealtimeEnDat:

The position value, status word, timestamp and trigger counter for an axis of the EIB 741 are read and displayed. The EIB 741 is operated in Soft Realtime mode for this. The axis is configured for EnDat 2.2 encoders. The user can select which of the four axes is to be displayed.

Furthermore, the user can choose between external and internal triggering.

The position values are continually read in a loop. The IP address of the EIB 741 is interrogated after the program has been started.

streaming:

The position value, status word, timestamp and trigger counter for an axis of the EIB 741 are read and displayed. The EIB 741 is operated in Streaming mode for this. Data for four axes is transmitted. The user can select which of the four axes is to be displayed. Furthermore, the user can choose between external and internal triggering. The position values are continually read in a loop. The IP address of the EIB 741 is interrogated after the program has been started.

recording:

The position value, status word, timestamp and trigger counter for a selectable axis are recorded in the EIB 741. The EIB 741 is operated in Recording mode for this. The data package is configured such that only the

data for the corresponding axis is recorded. After the recording phase, the data is transmitted to the PC and displayed. The IP address of the EIB 741 is interrogated after the program has been started. The user can choose between external and internal triggering.

TriggerIO:

The position value, status word, timestamp and trigger counter for an axis of the EIB 741 are read and displayed. The EIB 741 is operated in Soft Realtime mode for this. All axes are configured for incremental encoders. The user can select which of the four axes is to be displayed. Triggering occurs via an internal timer trigger. In addition to this, the trigger signal is output at trigger output 1. The IP address of the EIB 741 is interrogated after the program has been started.

TriggerRI:

The position value, status word, timestamp and trigger counter for a selectable axis of the EIB 741 are read and displayed. The EIB 741 is operated in Soft Realtime mode for this. Triggering is done via the reference mark of the encoder. The IP address of the EIB 741 is interrogated after the program has been started.

Labview examples

/EIB7Info:

AuxAxis:

The position values of the encoder at axis 1 can be saved via two different trigger sources. The auxiliary axis is used for this purpose. An encoder with incremental signals must be connected to axis 1. The position values are saved periodically via the internal timer trigger. At the same time, the position can be saved with a second, asynchronous trigger signal, Software Trigger 1. Both position values are displayed

/EIB7Info:

GetConnInfo:

The data of all currently open connections to the EIB 741 is output. This includes the IP address and port number for the TCP connections on both the EIB 741 and host.

GetNetworkSettings:

The settings for the network interface of the EIB 741 are read and displayed.

SetNetworkSettings:

The settings for the network interface of the EIB 741 can be changed. When the program is run, the settings are changed to those of the values entered in the entry fields. These take effect after the next reset.

/Polling:

PollEncoderData:

The trigger counter, position value, status word and timestamp for an axis of the EIB 741 are output. The axis is configured for incremental encoders. One position value is interrogated each time the program is run. The EIB 741 is operated in Polling mode.

PollIncrEnDatPosition:

An axis of the EIB 741 is configured for EnDat 01. The EnDat and incremental position are read simultaneously.

PollPosition:

The position values and status word for axes 1 to 4 are called cyclically. The axes can be configured individually for incremental encoders or for EnDat 2.1 or EnDat 2.2. The EIB 741 is operated in Polling mode.

/SoftRealtime:

SoftRealtime:

The position value, status word, timestamp and reference positions for axes 1 and 2 of the EIB 741 are read and displayed. The EIB 741 is operated in Soft Realtime mode for this. The user can choose between external and internal triggering. If internal triggering is selected, then the interval for the timer trigger can be set. The axes are configured for incremental encoders, and the position values are continuously read in a loop. Additionally, recording of the reference mark is activated at the start.

SoftRealtime_EnDat:

Axis 1 is configured for an incremental encoder, and axis 2 is configured for an EnDat 2.2 encoder. In addition, two reference marks are stored for the incremental encoder, and their values are transmitted. Various pieces of additional EnDat information are polled cyclically from the EnDat encoder. The EIB 741 is operated in Soft Realtime mode. The user can choose between external and internal triggering. If internal triggering is selected, then the interval for the timer trigger can be set.

/Streaming:

Streaming:

The position value and status word for axes 1 and 2 of the EIB 741 are read and displayed. The EIB 741 is operated in Streaming mode for this. The user can choose between external and internal triggering. If internal triggering is selected, then the interval for the timer trigger can be set. The axes are configured for incremental encoders, and the position values are continuously read in a loop. At the same time, the FIFO for buffering of data in the EIB is monitored, and its status is displayed.

/Recording:

Recording:

The position value, status word and timestamp for axes 1 and 2 are recorded in the EIB 741. The EIB 741 is operated in Recording mode for this. The user can choose between external and internal triggering. If internal triggering is selected, then the interval for the timer trigger can be set. At the same time, the memory of the EIB 741 is monitored, and the number of samples already saved is shown. The user can end the recording phase. The data is then transmitted to the PC, and the curve of the position values is shown graphically in a diagram.

/Trigger:

ExtTriggerOutput:

The position value, the status word and the timestamp for axes 1 and 2 of the EIB 741 are read and displayed. The EIB 741 is operated in Soft Realtime mode for this. All axes are configured for incremental encoders.

Triggering occurs via the internal timer trigger. In addition to this, the trigger signal of the internal timer is output at trigger output 1.

IntervalCounter:

The encoder at axis 1 generates trigger pulses depending on the current position. The position of axis 2 is saved and displayed via this trigger source. The trigger pulse interval can be set.

PulsCounter:

The EIB 741 is operated in Recording mode and axes 1 and 2 are configured for incremental encoders. Triggering occurs via an internal timer trigger. The first trigger pulse is released by the software trigger and the number of trigger pulses is limited to a defined number by the PulsCounter. After measurement, the recorded position values are shown in a diagram.

RI_Trigger:

The position value, status word, timestamp and trigger counter for an axis of the EIB 741 are read and displayed. The EIB 741 is operated in Soft Realtime mode for this. Triggering is done via the reference mark of the encoder.

5. Tools

networksettings:

The settings for the network interface of the EIB 741 can be changed. This includes the IP address, network mask, standard gateway, the settings for the DHCP client and the host name.

6. Contact

HEIDENHAIN

DR. JOHANNES HEIDENHAIN GmbH
Dr.-Johannes-Heidenhain-Straße 5
83301 Traunreut, Germany

Tel.: +49 8669 31-0
E-mail: info@heidenhain.de

Measurement systems (EIB741 Support)
Tel.: +49 8669 31-3104
E-mail: service.ms-support@heidenhain.de

www.heidenhain.de